



PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 22/04/2026

It is certified that an inspection team head by Panchayath Development officer, MAHESHA(Name of Officers with designation) from Bilagumba Gram Panchayath (RPR)(Name of Department /Office) inspected the Natus International School, Bilagumba(Name & Address of the school on 21/03/2026 (date of inspection) and found that theNatus International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the Central/

State/ U.T. Govt.

The above is valid for a period of 31/03/2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

ಪಂಚಾಯತಿ ಅಭಿವೃದ್ಧಿ ಅಧಿಕಾರಿ

ಬಿಳಗುಂಬ ಗ್ರಾಮ ಪಂಚಾಯತಿ

ಕನಕ ಚೋಟಿ, ಕಾಮನಗರ-ತಾಲ್ಲೂಕು

To

PrincipalNatus International SchoolBilagumba

(Name & Address of the Institution)

PRINCIPAL

NATUS INTERNATIONAL SCHOOL

Affiliated to CBSE Board, New

Affiliation No. 831334, Bilagumba

Ramanagara - 562

- The Filled up certificate should be either in Hindi or English. If it is issued in vernacular language translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



District Water Quality Testing Laboratory Ramanagara
Office of Executive Engineer, Rural Drinking Water & Sanitation Division,
3rd Floor, Silla Panchayath Bhawan, Bangalore South District - 562159, Karnataka.
Email: rdwsd.wqmstp.ramanagarlab@gmail.com

TEST REPORT					
Name and Address of the location: Natus International School, Bangalore-Mysore Express Highway, Bilugumba Road, Ramanagara Bangalore South District.				Report date:25.03.2026	
				Reference: Sample receipt form	
				Sample receipt date:23.03.2026	
				Sample code:RNG26MAR0017-P	
				Date of sample collection: 23.03.2026	
				Analysis start date:24.03.2026	
				Analysis completion date: 24.03.2026	
Sample collection protocol: APHA 24 th Edition				Sample quantity:1 Litre	
Sample Particulars: Drinking Water(RO)					
Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012	Permissible Limit IS 10500 : 2012	Protocol
Description: Colourless liquid.					
1.	pH Value @25 °C	5.88	6.5 - 8.5	No relaxation	IS 3025 (Part-11) : 2022
2.	Electrical Conductivity, μ S/cm @25 °C	92	-	-	IS 3025 (Part-14) : 2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6): 2018
4.	Colour, Hazen Units	05	5	15	IS 3025 (Part-4) :2021
5.	Turbidity, NTU	< 0.5	1	5	IS 3025 (Part-10) : 2023
6.	Total Dissolved Solids @ 180°C, mg/l	46	500	2000	IS 3025 (Part-16) : 2023
7.	Alkalinity as CaCO ₃ , mg/l	28.0	200	600	IS 3025 (Part-23) : 2023
8.	Total Hardness as CaCO ₃ , mg/l	40.44	200	600	IS 3025 (Part-21) : 2009
9.	Calcium as Ca, mg/l	8.10	75	200	IS 3025 (Part-40) : 2024
10.	Magnesium as Mg, mg/l	4.91	30	100	IS 3025 (Part-46) : 2023
11.	Chloride as Cl, mg/l	15.8	250	1000	IS 3025 (Part-32) : 1988
12.	Sulphate as SO ₄ , mg/l	1.46	200	400	IS 3025 (Part-24/Sec 1) : 2022
13.	Fluoride as F, mg/l	0.11	1	1.5	APHA 24 th Edition 4500- F D: 2023
14.	Nitrate as NO ₃ , mg/l	< 1.0	45	No relaxation	APHA 24 th Edition 4500- NO ₃ B : 2023
15.	Iron as Fe, mg/l	< 0.1	1	No relaxation	IS 3025 (Part-53) : 2024
Remarks: The given sample conforms to the limits of IS 10500 : 2012 Drinking Water Specification for the above tested parameters only.					
RDWSD Water Quality Lab Ramanagara.				Reviewed By	
				Authorized Signatory (Deepika N D, Technical Manager)	

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

Principal
NATUS INTERNATIONAL SCHOOL
Affiliated to CBSE Board, New
Affiliation No. 831334, Bilugumba R.
Ramanagara - 562159