



Phone No-080-29761529
Email Id- rfosouthblr@gmail.com

No.112/Education/CC/RFO/Bng-South/2026

Dated: 14-05-2026

१,

Principal,

M/s. Natus International School,

Vaidya Vidyalyaya Charitable Trust(R),

No-75, Bilagumba Road, Bilagumba Panchayat,

Ramanagara Taluk,

Bengaluru South District-562 159.

ಮಾನ್ಯರೇ,

ವಿಷಯ : M/s. Natus International School, Vaidya Vidyalaya Charitable Trust(R), ನಂ 75, ಬಿಳಗುಂಬ ರಸ್ತೆ, ಬಿಳಗುಂಬ ಪಂಚಾಯತ್, ರಾಮನಗರ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ಜಿಲ್ಲೆ-562 159. ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಕಟ್ಟಡಕ್ಕೆ ಸಮಾಪನ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.

ಉಲ್ಲೇಖ : 1) ಸಲಹಾ ಪತ್ರ ಸಂ. No.104/Education/FSR/RFO/Bng-South/2026

ದಿನಾಂಕ: 11-05-2026

2) ನಿಮ್ಮ ಪತ್ರ ದಿನಾಂಕ: 11-05-2026.

<<<<<<<>>>>>>>>

ನಂ 75, ಬಿಳಗುಂಬ ರಸ್ತೆ, ಬಿಳಗುಂಬ ಪಂಚಾಯತ್, ರಾಮನಗರ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ಜಿಲ್ಲೆ-562 159. ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 17.65 ಮೀಟರ್ ಎತ್ತರದ ನೆಲ ಹಂತ ಮತ್ತು 04 ಮೇಲಂತಸ್ತುಗಳನ್ನು ಹೊಂದಿರುವ M/s. Natus International School, Vaidya Vidyalaya Charitable Trust(R), ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ಈ ಮೇಲಿನ ಉಲ್ಲೇಖ (1) ರಂತೆ ದಿನಾಂಕ:11-05-2026 ರಂದು ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ ಅಗ್ನಿಶಮನ ಸಲಹಾ ಪತ್ರ ನೀಡಲಾಗಿದೆ.

ಉಲ್ಲೇಖ (2) ರ ನಿಮ್ಮ ಪತ್ರದಲ್ಲಿ, ಸದರಿ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಕಾರ್ಯ ಮುಗಿದಿದ್ದು, ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಮಾಪನ ಪತ್ರ ನೀಡುವಂತೆ ಕೋರಿರುವಿರಿ.

ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ, ಜಿಲ್ಲಾ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ರಾಮನಗರ ಅಗ್ನಿಶಾಮಕ ಠಾಣೆ, ಕರ್ನಾಟಕ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು ರವರು ದಿನಾಂಕ: 14-05-2026 ರಂದು ನಂ 75, ಬಿಳಗುಂಬ ರಸ್ತೆ, ಬಿಳಗುಂಬ ಪಂಚಾಯತ್, ರಾಮನಗರ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ಜಿಲ್ಲೆ-562 159 ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಣೆ ಮಾಡಿ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯು ನೀಡಿರುವ ಸಲಹಾ



ಪತ್ರದಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ, ಅಗ್ನಿ ನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಪೂರ್ಣವಾಗಿ ಅನುಷ್ಠಾನಗೊಳಿಸಿರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದಲ್ಲಿನ ನೌಕರರು/ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತ ತರಬೇತಿ ಮಾತ್ರ ಬಾಕಿ ಇರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದ ಸಮಾಪನ ಪತ್ರ ತರುವಾಯ ಅದರಲ್ಲಿನ ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತು ತರಬೇತಿ ವ್ಯವಸ್ಥಿಸಲು ಸಾಧ್ಯವಾಗುತ್ತದೆಂದು ತಿಳಿಸಿರುತ್ತಾರೆ.

ಆದ್ದರಿಂದ ನಂ 75, ಬಿಳಿಗುಂಬ ರಸ್ತೆ, ಬಿಳಿಗುಂಬ ಪಂಚಾಯತ್, ರಾಮನಗರ ತಾಲ್ಲೂಕು, ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ಜಿಲ್ಲೆ-562 159. ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 17.65 ಮೀಟರ್ ಎತ್ತರದ ನೆಲ ಹಂತ ಮತ್ತು 04 ಮೇಲಂತಸ್ತುಗಳನ್ನು ಹೊಂದಿರುವ M/s. Natus International School, Vaidya Vidyalaya Charitable Trust(R), ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಲಹಾ ಪತ್ರ ಸಂ. No.104/Education/FSR/RFO/Bng-South/2026 ದಿನಾಂಕ:11-05-2026 ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಹಾಗೂ ಅಗ್ನಿ ನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸಬೇಕೆಂದು ಹಾಗೂ ನಿಮ್ಮ ಮುಚ್ಚಳಿಕೆ ಪತ್ರ ದಿನಾಂಕ 14-05-2026 ರಲ್ಲಿ ಒಪ್ಪಿರುವಂತೆ, ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳನ್ನು ಸುಸ್ಥಿತಿಯಲ್ಲಿಡಬೇಕೆಂಬ ಹಾಗೂ ಕಟ್ಟಡದಲ್ಲಿನ ಶೇಕಡಾ 40% ರಷ್ಟು ಸಿಬ್ಬಂದಿ/ನೌಕರರಿಗೆ ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಕ್ರಮಗಳ ಬಗ್ಗೆ ಬೆಂಗಳೂರಿನ ಆರ್.ಎ. ಮುಂಡ್ಕರ್ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ಅಕಾಡೆಮಿಯಲ್ಲಿ ಸೂಕ್ತ ತರಬೇತಿಯನ್ನು 03 ತಿಂಗಳೊಳಗೆ ಪಡೆಯಲು ವ್ಯವಸ್ಥಿಸಬೇಕೆಂಬ ಷರತ್ತಿನ ಮೇಲೆ ಸಮಾಪನ ಪತ್ರವನ್ನು ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ಇಲಾಖೆಯಿಂದ ನೀಡಲಾಗಿದೆ.

ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವು ದಿನಾಂಕ:-10-05-2028 ವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. ತದನಂತರ ಈ ಸಮಾಪನ ಪತ್ರವನ್ನು ನವೀಕರಿಸುವಂತೆ ತಿಳಿಸಲಾಗಿದೆ.

ಹಾಗೆಯೇ ಒಂದು ವೇಳೆ ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಇಲಾಖೆಯ ಶಿಫಾರಸ್ಸಿನನ್ವಯ ಅಳವಡಿಸಿರುವ ಅಗ್ನಿನಿವಾರಣೆ ಹಾಗೂ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳು ಸುಸ್ಥಿತಿಯಲ್ಲಿರದೇ ಇರುವುದು ಕಂಡು ಬಂದರೆ ಅಥವಾ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸದಿದ್ದರೆ ಅಥವಾ ಕಾನೂನಿನನ್ವಯ ಸದರಿ ಕಟ್ಟಡದ ಸುತ್ತ ಬಿಟ್ಟಿರುವ ತೆರೆದ ಪ್ರದೇಶದಲ್ಲಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ರಚನೆಗಳನ್ನು ನಿರ್ಮಾಣ ಮಾಡಿದರೆ ಅಥವಾ ಯಾವುದೇ ರೀತಿಯ ಖಾಯಂ/ತಾತ್ಕಾಲಿಕ ಅಡಚಣೆಗಳನ್ನು ಉಂಟು ಮಾಡಿದರೆ, ಈ ಸಮಾಪನ ಪತ್ರವು ಅನುರ್ಬಂಧಗೊಳ್ಳುವುದು ಹಾಗೂ ಕಾನೂನಿನ ಚೌಕಟ್ಟಿನಲ್ಲಿ ಮುಂದಿನ ಕ್ರಮ ಕೈಗೊಳ್ಳಲಾಗುವುದು ಎಂಬುದಾಗಿ ಸೂಚಿಸಲಾಗಿದೆ.

ಪ್ರಾದೇಶಿಕ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ 14/5/26
ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ವಲಯ
ಬನ್ನೇರುಘಟ್ಟ ರಸ್ತೆ, ಬೆಂಗಳೂರು-29

1) ಪ್ರತಿಯನ್ನು ಗೌರವಗಳೊಂದಿಗೆ,

ಮಾನ್ಯ ಪೊಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರು ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು,
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು.

2) ಜಿಲ್ಲಾ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ,

ರಾಮನಗರ ಅಗ್ನಿಶಾಮಕ ಠಾಣೆ
ಬೆಂಗಳೂರು ದಕ್ಷಿಣ ಜಿಲ್ಲೆ.

Office of the Regional Fire Officer,
Bangalore South Zone,
Karnataka State Fire and Emergency
Services, Bannerghatta Main Road,
Bangalore 560029.

No.112/Education/CC/RFO/Bng-South/2026

Dated 14-05-2026

To:
Principal,
M/s Natus International School,
Vaidya Vidyalaya Charitable Trust (R)
No.75, Bilagumba Road, Bilagumba Panchayat,
Ramanagara Taluk,
Bengaluru South District 562 159.

Sir,

Sub: Regarding issuing Safety measurement certificate which built in
No.75, Bilagumba Road, Bilagumba Panchayat, Ramanagara Taluk,
Bengaluru South District 562 159. by M/s Natus International School,
Vaidya Vidyalaya Charitable Trust (R)

Ref : 1. Advisory Letter No.104/Education/FSR/RFO/Bng-South/2026,
dated 11-05-2026.
2. Your letter dated 11-05-2026.

The M/s Natus International School, Vaidya Vidyalaya Charitable Trust (R) No.75,
Bilagumba Road, Bilagumba Panchayat, Ramanagara Taluk, Bengaluru South District
562159 the building is having a 17.65 meter high ground floor and 04 upper floors
constructed here, and the Fire and Emergency Services Department has issued a Fire
Advisory Letter as per reference (1) above on dt.11.05.2026 for educational building as
per your request.

As mentioned in reference(2), of your letter, you have requested the Fire and
Emergency Services Department to issue a completion certificate stating that the
installation of fire fighting equipments in the said educational building has been
completed.

As per your request, the District Fire Officer, Ramanagara Fire Station, Karnataka
Fire and Emergency Services, on 14.05.2026, inspected the educational building
constructed at No.75, Biligumba Road, Biligumba, Ramanagara Taluk, Bangalore South
District 562 159, and as per the took stock of the advisory given by the Fire and Emergency
Services Department letter, it has been stated that fire protection and control, installation



of fire extinguishing equipment and safety measures have been fully implemented in the said educational building and that only fire extinguishing training is pending for the employees/staff in the building and that after the completion letter of the said building, fire extinguishing training will to arrange be available for the staff in it.

Therefore, As per mentioned in the Advisory letter No.104 / Education /FSR /RFO /Bng-South/2026,dated 11.05.2026 of Fire Extinguishing and Emergency Services department for educational building of No.75, Biligumba Road, Biligumba, Ramanagara Taluk, Bangalore South District 562 159, of M/s Natus International School, Vaidya Vidyalaya Charitable Trust (R), with the fire protection and control and installation of fire extinguishing equipment and safety measures to be strictly followed and as agreed in your letter of undertaking dated 14-05-2026, the fire extinguishing equipment should be kept in good condition and 40% of the staff/ employees in the building should be informed about fire protection and control measures, in this regard, The letter has been issued by the Fire and Emergency Services Department on the condition that arrangements should be made to undergo appropriate training at the R.A.Mundkur Fire Extinguishing and Emergency Services Academy, Bangalore.

This completion certificate is valid till the date of 10.05.2028. Thereafter, this completion certificate is required to be renewed.

It is also advised that if at any time fire protection and fire extinguishing equipment installed as per the department's recommendations is found to be inoperative or the safety measures are not strictly followed or any additional structures are constructed in the open area left by law around the said building or any kind of permanent /temporary obstruction is caused, this completion letter will be void and further action will be taken within the framework of the law.

Sd/-

Regional Fire Officer,
Bangalore South Zone,
Bannerghatta Road, Bangalore-29

1) Copy with respect :

The Hon'ble Director General of Police and Director General
of Karnataka State Fire and Emergency Services,

2) District Fire Officer,

Ramanagara Fire Station,
Bangalore South District.

*Translated from
Kannada to English*

Ravi V
(RAVI.V)

Typist / Translator
D.C. Compound, K.G. Road
Bangalore - 560 009



ATTESTED BY ME

[Signature]
BASAVARAJA, B.Com., LL.B.
ADVOCATE & NOTARY PUBLIC
GOVT. OF INDIA
BANGALURU URBAN